



# City of Seattle Preliminary Assessment Report

May 14, 2010

This report represents a preliminary determination of project requirements from various city departments. The report is based on project characteristics that you identified on the Site Plan and the Preliminary Application Form, and on your Pre-Application Site Visit (PASV). The city's goal is to provide you with as much information and assistance as possible prior to your permit application submittal. This coordinated list of requirements and decisions is a reference for creating a more complete submittal package to reduce the need for correction cycles that delay permit approval. The information in this report can also be used to develop a Street Improvement Plan (SIP) application for submittal to SDOT (see SDOT Client Assistance Memos 2200, 2201, 2211, 2212, 2213, and 2214).

**Note:** A preliminary assessment is being conducted on all land use projects as well as new construction projects. If you have a building project associated with your land use project, the preliminary assessment will not be repeated on the building project.

**The applicant assumes full responsibility for determining all permit requirements and infrastructure improvements per applicable sections of the Seattle Municipal Code and the City of Seattle's Right-of-Way Improvement manual.**

- Street use permits are required for all work in the right-of-way (see SDOT Client Assistance Memo 2100).
- If street improvements are required, you must obtain all necessary permits from SDOT.
- If an SIP is required, SDOT must accept your 90% complete SIP before DPD construction intake (see Client Assistance Memos 2200, 2206, 2209, 2211, 2213, and 2214).

Project Summary			
AP/Project No.	6227314	Ground Disturbance	Y
Application Template	BLDG	PASV Required This Permit	Y
Application Type	CONSTRUCTION AND DEVELOPMENT	Date PASV Completed	05/05/10
Category	MULTIFAMILY	PASV Done Under	
DPD Review Type	FULL	Permit Remarks	
Address	4309 7th Ave NE		
Location			
Zoning	L3	Applicant	CHIP KOUBA 203 N 36TH STE SUITE 201 SEATTLE WA 98103 (206) 226-1607
King County APN	<a href="#">4092300715</a>		
Permit Status	Initial Information Collected		
Description of Work	Demolish existing house and shed. Construction of (5) new Townhouses.	Applicant Email	<a href="mailto:chip@eccodesigninc.com">chip@eccodesigninc.com</a>
		Linked AP/Project Nos.	
SDOT Project No			

For detailed zoning information, click the King County APN number above, or visit <http://web1.seattle.gov/dpd/parceldata/> to find zoning details about your address.

## Pre-Application Site Visit (PASV) Report

**Contact:** Ede M Courtenay, (206) 733-9679, [Ede.Courtenay@seattle.gov](mailto:Ede.Courtenay@seattle.gov)

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all**

**required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 18 months of the above inspection date. After 18 months, the applicant must apply for another PASV. No extensions will be granted.

## **ECA Mapping Unit and Type**

Non-ECA

## **Earth Disturbance**

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

## **Existing ROW Conditions**

### **7TH AVE NE**

Street conditions:

Concrete paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5" inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way. There is an inlet on the west side of 7th st 47th. It is currently not functioning.

### **NE 43RD ST**

## **Tree Protection**

Existing trees appear to be shown accurately on the site plan

## **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual (DR 16-2009, Volume 2). The CSC Best Management Practices (BMPs) noted below can be found in the Construction Stormwater Control Technical Requirements Manual, available online and from DPD's Public Resource Center.

### **Show the following on the CSC/Post Construction Soil Amendment Plan:**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or online at: <http://web1.seattle.gov/DPD/InspectionRequest>

## **Inspectors Notes**

Photo-documented. No unusual conditions observed. No basement, no trees, power pole in the planting strip at the NE corner of the site.

## **Seattle City Light Requirements**

**Contact:** Ray Ramos, (206) 615-1193, [ray.amos@seattle.gov](mailto:ray.amos@seattle.gov)

## Easements

SCL power easement is required. Property survey may be required at project's expense.

SCL blanket power easement over the entire parent parcel is required. Property survey may be required at project's expense. If this is a Unit Lot Subdivision, a blanket easement is needed.

## Conservation

Built Smart Programs - SCL offers developers of 5+ unit multifamily buildings incentives for installation of energy efficiency measures. Build your building more efficiently with our help! For more information, contact Pete Held at (206)684-3605 or e-mail, [peter.held@seattle.gov](mailto:peter.held@seattle.gov).

## Other Requirements

- For new service, an Application for Electrical Service must be submitted to Seattle City Light. Please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. The Electrical Service Representative should also be contacted to coordinate electrical details with demolition and temporary power for construction. Your Electrical Service Representative is: Elifonso Leal, 206-684-4988, [elifonso.leal@seattle.gov](mailto:elifonso.leal@seattle.gov)

## DPD Drainage Requirements

**Contact:** Joseph P Berentsen, (206) 684-8613, [Joe.Berentsen@seattle.gov](mailto:Joe.Berentsen@seattle.gov)

The following requirements are based on the current stormwater and side sewer codes. Major updates to these codes are expected in the fourth quarter of 2009.

### Existing Public Drainage Infrastructure

Sanitary sewer main location: 7th Ave.NE

Sanitary sewer main size: 10" Diameter

Storm drainage main location: 7th Ave. NE

Storm drainage main size: 15" Diameter

### Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Weep hole.

#### Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. Refer to CAM 531, Post Construction Soil Management. For projects with 5,000 square feet or more of new plus replaced impervious surface, a comprehensive drainage control plan and construction stormwater control plan shall be prepared by a licensed engineer.

Parcel-based projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible without causing flooding, landslide, or erosion impacts per SMC 22.805.020.F. Refer to Director's Rule 19-2009 - Requirements for Green Stormwater Infrastructure to the Maximum Extent Feasible and Director's Rule 17-2009 - Stormwater Manual Vol. III - Stormwater Flow Control and Water Quality. Submit a GSI Calculator per DR 19-2009.

#### Water Quality

No requirements

### Wastewater

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a King County Capacity Charge. Further information is available online at:

<http://www.kingcounty.gov/environment/wastewater/capacitycharge.aspx>

### Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge (DPD DR 3-2006/SPU DR 02-06 VII.H) is located at the following: Onsite (infiltration).

## DPD Land Use Code Requirements

**Contact:** Justina T Guyott, (206) 233-7898, [justina.guyott@seattle.gov](mailto:justina.guyott@seattle.gov)

## Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowimanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

### 7TH AVE NE

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found at

[http://www.seattle.gov/dpd/static/Covenant\\_Consenting\\_LID\\_LatestReleased\\_DPDS\\_006060.pdf](http://www.seattle.gov/dpd/static/Covenant_Consenting_LID_LatestReleased_DPDS_006060.pdf)

Existing curbcuts that will no longer be used are required to be removed, and the curbline reinstalled, per SDOT standards.

### NE 43RD ST

Grading to future ROW grade. See <http://www.seattle.gov/transportation/gradesheetintro.htm>

New structures must be designed to accommodate future right-of-way improvements. To ensure that driveways and pedestrian access points are designed to match these future street improvements, please use the Building Grade Calculator, which can be found at

<http://www.seattle.gov/transportation/gradesheetintro.htm>

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found at

[http://www.seattle.gov/dpd/static/Covenant\\_Consenting\\_LID\\_LatestReleased\\_DPDS\\_006060.pdf](http://www.seattle.gov/dpd/static/Covenant_Consenting_LID_LatestReleased_DPDS_006060.pdf)

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.

<http://www.seattle.gov/transportation/treeplanting.htm>.

Landscaping is required to be installed in the planting strips in the right-of-way. Contact SDOT Urban Forestry to determine species of landscaping and standards of planting. For residential projects, call (206) 684-TREE; for all others, call (206) 684-5693. Please add a note to the site plan showing size, location and species of shrubs and groundcover to be planted.

A vehicular turnaround/cul-de-sac is required when street or alley dead-ends at the property to be developed. Apply for SDOT SIP design guidance (see SDOT CAM 2211).

## SDOT Requirements

**Contact:** Matthew Tabalno, [matthew.tabalno@seattle.gov](mailto:matthew.tabalno@seattle.gov)

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

## Street Improvement Requirements

### NE 43RD ST

New/replacement turnaround/cul-de-sac: See Seattle Right of Way Improvements Manual (ROWIM) section 4.22. If your project is proposing to install new turnaround/cul-de-sac or is proposing to change the alignment of an existing turnaround/cul-de-sac apply for SDOT SIP Design Guidance. See SDOT CAM 2211.

## SPU Requirements

**Contact:** Steve Resnick, (206) 233-7234, [ResnicS@seattle.gov](mailto:ResnicS@seattle.gov)

### Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

## Water Availability

**Contact:** SPU Water

Your water availability assessment is in progress. System improvements may be required; the extent of those improvements will be sent to you on your Water Availability Certificate.

Water Availability Certificate reference number: 20100239

Water Availability Certificate status: Approved with No Changes

Prepared by: Karen Young

### Existing Water System Information

Proximity of nearest fire hydrant is: 180 feet SE of property. Meets standards.

Water Main:

Size: 8 inches

Material: Cast Iron

Class: B

- Standard

- Abutting

Water Main is available to serve in: 7th Avenue NE

Distance of main to W margin of street is 40 feet.

Public ROW width is 60 feet.

Water Service(s):

Size: 3/4"

Material: Copper

### Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD CAM 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to CAM 208 for information regarding the application requirements for a SEPA review and CAM 3000 for information regarding landmarks and historic preservation.

### Applicant Next Steps

For questions on the permit application process, please contact the Applicant Services Center (ASC) at 206-684-8850.

1. Review the requirements in this report.
2. Use Client Assistance Memos (CAMs), checklists and standards, and 5 Steps for a Successful DPD Application Submittal (available on the DPD website) for additional information.
3. If a SIP is required, **DPD will not accept your application until your SIP application is screened at SDOT**. Allow a minimum of 5 days for screening after application submittal to SDOT.
4. Information on requirements for Electric Service Connection (RESC), electric service applications, guidelines and other services can be found on Seattle City Light's website (<http://www.seattle.gov/light/newconstruction/>). Contact an Electric Service Representative for your electrical service design and connection questions:  
North of Denny Way (206) 615-0600  
South of Denny Way (206) 386-4200  
Large Commercial & Industrial (206) 233-7177  
Service Applications (206) 233-APPS (2777)
5. If you have additional questions or need additional information, you may request a pre-submittal conference. Call (206) 684-8850 or go to DPD's website ([http://www.seattle.gov/dpd/Publications/Forms/Building\\_Permit/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp)).
6. When all issues have been addressed, you may schedule an intake appointment with DPD. **Please bring a copy of this report to your intake appointment.**

The requirements and determinations in this report are based on the details provided by the applicant on the preliminary application form and site plan submitted to DPD. If the scope of your proposed project changes before your DPD intake appointment or SDOT SIP application, the requirements in this report are subject to change. If there are municipal code and ordinance changes prior to your DPD intake, the project must meet the

new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.